




PRODUCT TYPE A*LDS

Double Compression Gland designed for use with Unarmoured Cable

Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2 : AEx e : AEx ta



REFERENCE NUMBER: 2.2.0

EXAMPLE PART NUMBERING:
A2LDSBF/NP/20/M20

A	Gland featuring controlled displacement sealing
2	Neoprene Seals (2) - Silicone Seals (3) - Neoprene/Lead (1) - Silicone/Lead (4)
L	Peppers Standard Designation
DS	Double Sealing
B	Aluminium (A) / Brass (B) / Stainless Steel (S)
F	Multiple Certification
C	PVC Shroud (C) - PCP Shroud (P) - LSOH Silicone Shroud (3)
K-V-H	Locknut & Nylon (K), Fibre (V) or PTFE (H) IP Washer
T	Including Earth Tag
S	Including Serrated Washer
1	Quantity per kit
NP	Nickel Plated
20	Gland shell size
M20	M20 x 1.5mm Male Entry Thread

OPTIONAL ACCESSORIES:

LOCKNUT	Brass (ACBLN) / St Steel (ACSLN) / Aluminium (ACALN)
EARTH TAG	Brass (ACBET) / St Steel (ACSET) / Aluminium (ACAET)
IP WASHERS	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
SERRATED WASHERS	Stainless Steel (ACSSW)
SHROUDS	PVC (ACSPVC) / PCP (ACSPCP) / LSOH Silicone (ACSSIO)

IP RATING:	IP66 & IP68 (50 metres - 7 Days), Type 4X
OPERATING TEMP:	Neoprene Seals -35°C to +90°C / Silicone Seals -60°C to +180°C
MATERIALS:	Aluminium, Brass or Stainless Steel
PLATING:	Electroless Nickel

PART NUMBERS:

A	1	L	DS	B	F
	2			S	
	3			A	
	4				



PRODUCT DESCRIPTION

"A*LDS" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Commonly referred to as "double seal stuffing glands", they provide two controlled pull resistant environmental displacement seals on the cable outer sheath, minimising damage to cables that exhibit "cold flow" characteristics. The gland maintains IP66 & IP68 to 50 metres. It is supplied with an IP O-ring seal as standard on metric entry threads. Options are available for use with LSOH cables and extreme temperature applications.

COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529
C22.2 (see certificate), CAN/CSA 60079-0/1/7, UL514B, UL1203, UL2225, UL50E ANSI/UL 60079-0/7, ISA 60079-31

CERTIFICATION:

ATEX	II 1D 2G Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc
IECEX	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da
CEC - Canada (except size 12)	Class I Division 2, Groups A, B, C & D Class II Division 1, Groups E, F & G Class III, Enclosure Type 4X Class I Zone 1 Ex d IIC / Ex e II
NEC - USA	Class II Division 1, Groups E, F & G Class III, Enclosure Type 4X Class I Zone 1 AEx e IIC Gb Class II Zone 20 AEx ta IIIC Da
EAC	1Ex d II Gb X / 1Ex e IIC Gb X / 2Ex nR IIC Gc X / Ex ta IIIC Da X
INMETRO - Brazil	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc
SAC - China	Ex d IIC Gb / Ex e IIC Gb
UKRAINE	Ex d IIC X / Ex e II X
CCoE - India	Ex d IIC Gb (Zone 1) Ex e IIC Gb (Zone 2) Ex nR IIC Gc (Zone 2)
ABS	Specified ABS Rules
LLOYD'S	Ex d IIC Gb / Ex e IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da
RMRS	Ex d IC / Ex d IIC / Ex e IC / Ex e IIC / Ex ta IIIC / Ex tb IIIC

CERTIFICATION No:

ATEX	SIRA 01ATEX1272X & SIRA 09ATEX1221X
IECEX	IECEX SIR 07.0096X
CEC - Canada	CSA 1356011
NEC - USA	CSA 2627370
EAC	TC RU C-GB.BH02.B.00693-18
INMETRO - Brazil	NCC 13.2012 X
SAC - China	NEPSI GYJ16.1399X
UKRAINE	UA.TR.047.C.0408-13 & 2937
CCoE - India	PESO P365300/2 & P365300/5
ABS	14-LD463991-1-PDA
LLOYD'S	10/00056(E1)
RMRS	14.02755.315

CABLE GLAND SELECTION TABLE (ALL DIMENSIONS IN mm)

Gland Size	Entry Thread Size		Metric Thread Length [B]	Cable Acceptance Details Outer Sheath [D]		Nominal Protrusion Length [L] Metric	Dimensions/Weight (Metric)			Shroud Size (Metric)
	Metric	NPT		Min	Max		Across Flats [A]	Across Corners	Weight Kgs	
12	M12 x 1.5	3/8"	16	0.9	6.0	33	19.0	21.0	0.064	L19
12	M16 x 1.5	3/8" or 1/2"	16	0.9	6.0	33	25.4	28.0	0.119	L24
16	M16 x 1.5	1/2" or 3/4"	16	4.0	8.4	48	25.4	28.0	0.133	L24
20S	M20 x 1.5	1/2" or 3/4"	16	7.2	11.7	48	25.4	28.0	0.209	L24
20	M20 x 1.5	1/2" or 3/4"	16	9.4	14.0	62	30.0	33.0	0.275	L30
25	M25 x 1.5	3/4" or 1"	16	13.5	20.0	62	37.6	41.4	0.408	L38
32	M32 x 1.5	1" or 1 1/4"	16	19.5	26.3	62	46.0	50.6	0.408	L46
40	M40 x 1.5	1 1/4" or 1 1/2"	16	23.0	32.2	68	55.0	60.5	0.666	L55
50S	M50 x 1.5	1 1/2" or 2"	16	28.1	38.2	68	65.0	71.5	0.896	L65
50	M50 x 1.5	2"	16	33.1	44.1	74	65.0	71.5	0.736	L65
63S	M63 x 1.5	2" or 2 1/2"	19	39.2	50.1	74	80.0	88.0	1.330	L80
63	M63 x 1.5	2 1/2"	19	46.7	56.0	74	80.0	88.0	1.114	L80
75S	M75 x 1.5	2 1/2" or 3"	19	52.1	62.0	74	90.0	99.0	1.493	L90
75	M75 x 1.5	3"	19	58.0	68.0	74	90.0	99.0	1.218	L90
80	M80 x 2.0	3" or 3 1/2"	25	62.2	72.0	87	104.0	115.2	2.322	L104
85	M85 x 2.0	3" or 3 1/2"	25	69.0	78.0	87	104.0	115.2	2.107	L104
90	M90 x 2.0	3 1/2" or 4"	25	74.0	84.0	88	114.0	125.7	2.539	L114
100	M100 x 2.0	3 1/2" or 4"	25	82.0	90.0	90	114.0	125.7	2.211	L114

NOTES

- Gland size does not necessarily equate to the entry thread size.
- The IP O-ring seal is only available on metric entry threads. IP washers can be supplied for tapered entry threads.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.

Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.

- When selecting IP Washer & Shroud material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.