




# PRODUCT TYPE A8CF

## Single Compression Gland designed for use with Armoured and Unarmoured Flat Cables and featuring a Female Conduit Connection

Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2 : AEx e : AEx ta



REFERENCE NUMBER: 3.3.2

EXAMPLE PART NUMBERING:  
A8CFBFM20/NP/20/M20

<b>A</b>	Gland designed for use with Unarmoured Cables
<b>8</b>	Silicone Seal for Flat Cables
<b>CF</b>	Female Conduit Connection Thread
<b>B</b>	Brass (B) / Stainless Steel (S)
<b>F</b>	Multiple Certification
<b>M20</b>	M20 x 1.5 Female Conduit Connection Thread
<b>L</b>	Locknut (material dictated by gland entry thread material)
<b>N</b>	Including IP Washer, Nylon (N) - Fibre (V) - PTFE (H)
<b>T</b>	Including Earth Tag
<b>S</b>	Including Serrated Washer
<b>1</b>	Quantity per kit
<b>NP</b>	Nickel Plated
<b>20</b>	Gland shell size
<b>M20</b>	M20 x 1.5 Male Entry Thread

OPTIONAL ACCESSORIES:

<b>LOCKNUT</b>	Brass (ACBLN) / Stainless Steel (ACSLN)
<b>EARTH TAG</b>	Brass (ACBET) / Stainless Steel (ACSET)
<b>IP WASHERS</b>	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
<b>SERRATED WASHERS</b>	Stainless Steel (ACSSW)

<b>IP RATING:</b>	IP66 & IP68 (50 metres - 7 Days), Type 4X
<b>OPERATING TEMP:</b>	Silicone Seals -60°C to +180°C
<b>MATERIALS:</b>	Brass or Stainless Steel
<b>PLATING:</b>	Electroless Nickel

CABLE GLAND SELECTION TABLE  
(ALL DIMENSIONS IN mm)

Gland Size	Entry Thread Size		Metric Thread Length [B]	Connection Thread Options		Cable Outer Sheath [D]				Nominal Protrusion Length [L] (Metric)	Dimensions/Weight (Metric)		
	Metric	NPT		Metric	NPT	Width		Thickness			Across Flats [A]	Across Corners	Weight Kgs
						Min	Max	Min	Max				
20S	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	6.3	11.7	4.0	7.0	45	30.0	33.0	0.174
20R	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	8.1	13.5	5.8	6.2	46	30.0	33.0	0.175
20	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	10.3	13.5	5.6	9.0	45	30.0	33.0	0.174
25	M25 x 1.5	3/4" or 1"	16	M25 x 1.5	3/4" or 1"	10.6	16.2	4.0	7.0	48	37.6	41.4	0.194

NOTES

- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.

- Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.

PART NUMBERS:

A	8	CF	B	F
S				



### PRODUCT DESCRIPTION

"A8CF" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex d, IP sealing and have been tested to IP66 and IP68 to 50 metres. The "A8CF" version is designed to accommodate unarmoured and armoured cables where sealing and retention is required only on the outer sheath and additionally provides a male thread for the connection of conduit.

### COMPLIANCE STANDARDS:

EN60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31  
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529  
UL514B, UL1203, UL2225, UL50E, ANSI/UL 60079-0/7 & ISA 60079-31

CERTIFICATION:

<b>ATEX</b>	II 1D 2G Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc
<b>IECEx</b>	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da
<b>NEC – USA</b>	Class II Division 1, Groups E, F & G
<b>(except size 25)</b>	Class III, Enclosure Type 4X Class I Zone 1 AEx e IIC Gb Class II Zone 20 AEx ta IIIC Da
<b>EAC</b>	1Ex d II Gb X / 1Ex e IIC Gb X / 2Ex nR IIC Gc X / Ex ta IIIC Da X
<b>INMETRO – Brazil</b>	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc
<b>SAC – China</b>	Ex d IIC Gb / Ex e IIC Gb
<b>UKRAINE</b>	Ex d IIC X / Ex e II X
<b>CCoE – India</b>	Ex d IIC Gb (Zone 1) Ex e IIC Gb (Zone 2) Ex nR IIC Gc (Zone 2)
<b>ABS</b>	Specified ABS Rules
<b>LLOYD'S</b>	Ex d IIC Gb / Ex e IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da
<b>RMRS</b>	Ex d IC / Ex d IIC / Ex e IC / Ex e IIC / Ex ta IIIC / Ex tb IIIC

CERTIFICATION No:

<b>ATEX</b>	SIRA 01ATEX1270X & SIRA 09ATEX1221X
<b>IECEx</b>	IECEx SIR 05.0020X
<b>NEC – USA</b>	CSA 2627370
<b>EAC</b>	TC RU C-GB.BH02.B.00693-18
<b>INMETRO – Brazil</b>	NCC 13.2187 X
<b>SAC – China</b>	NEPSI GYJ16.1398X
<b>UKRAINE</b>	UA.TR.047.C.0408-13 & 2937
<b>CCoE – India</b>	PESO P365300/2 & P365300/6
<b>ABS</b>	14-LD463991-1-PDA
<b>LLOYD'S</b>	10/00056(E1)
<b>RMRS</b>	14.02755.315

3.3.2