



# PRODUCT TYPE E8XCF

## Double Compression Gland designed for use with Armoured Flat Cables featuring a Female Conduit Connection

Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68

### PART NUMBERS:

E	8	X	CF	B	F
					S



### PRODUCT DESCRIPTION

"E8XCF" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Developed for flat cables, they provide controlled Ex d sealing and have been tested to IP66 and IP68 to 50 metres. The "E8XCF" version is designed to accommodate armoured cables, sealing on the inner and outer sheaths and also incorporates a detachable armour specific clamping system. The gland features a female conduit connection thread as standard.

### COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31  
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529

CERTIFICATION:	ATEX	II 1D 2G Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da II 3G Ex nR IIC Gc
	IECEX	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da
	EAC	1Ex d II Gb X / 1Ex e IIC Gb X / 2Ex nR IIC Gc X / Ex ta IIIC Da X
CERTIFICATION No.:	INMETRO – Brazil	Ex db IIC Gb / Ex eb IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc
	SAC – China	Ex d IIC Gb / Ex e IIC Gb
	CCoE – India	Ex d IIC Gb (Zone 1) Ex e IIC Gb (Zone 2) Ex nR IIC Gc (Zone 2)
	LLOYD'S	Ex d IIC Gb / Ex e IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da

CERTIFICATION No.:	ATEX	SIRA 01ATEX1270X & SIRA 09ATEX1221X
	IECEX	IECEX SIR 05.0020X
	EAC	TC RU C-GB.BH02.B.00693-18
	INMETRO – Brazil	NCC 13.2187 X
	SAC – China	NEPSI GYJ16.1398X
	CCoE – India	PESO P365300/2 & P365300/6
	LLOYD'S	10/00056(E1)

REFERENCE NUMBER: 3.5.2

### EXAMPLE PART NUMBERING:

E8XCFB050NPT/NI/20/M20

<b>E</b>	Gland designed for use with Armoured Cables	
<b>8</b>	Silicone Seal for flat cables	
<b>X</b>	Detachable Clamping for Braid Armour	
<b>CF</b>	Female Conduit Connection Thread	
<b>B</b>	Brass (B) / Stainless Steel (S)	
<b>F</b>	Multiple Certification	
<b>050NPT</b>	1/2"NPT Female Conduit Connection Thread	
<b>OPTIONS</b>	<b>L</b>	Locknut (material dictated by gland entry thread material)
	<b>N</b>	Including IP Washer, Nylon (N) - Fibre (V) - PTFE (H)
	<b>T</b>	Including Earth Tag
	<b>S</b>	Including Serrated Washer
	<b>1</b>	Quantity per kit
	<b>NP</b>	Nickel Plated
<b>20</b>	Gland shell size	
<b>M20</b>	M20 x 1.5 Male Entry Thread	

### OPTIONAL ACCESSORIES:

<b>LOCKNUT</b>	Brass (ACBLN) / Stainless Steel (ACSLN)
<b>EARTH TAG</b>	Brass (ACBET) / Stainless Steel (ACSET)
<b>IP WASHERS</b>	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
<b>SERRATED WASHERS</b>	Stainless Steel (ACSSW)

<b>IP RATING:</b>	IP66 & IP68 (50 metres - 7 Days)
<b>OPERATING TEMP:</b>	Silicone Seals -60°C to +180°C
<b>MATERIALS:</b>	Brass or Stainless Steel
<b>PLATING:</b>	Electroless Nickel

### CABLE GLAND SELECTION TABLE (ALL DIMENSIONS IN mm)

Gland Size	Entry Thread Size		Metric Thread Length [B]	Conduit Connection Thread		Cable Inner Sheath [C]				Cable Outer Sheath [D]				Armour Acceptance Range	Nominal Protrusion Length [L] (Metric)	Dimensions/Weight (Metric)		
	Metric	NPT		Metric	NPT	Width Min	Width Max	Thickness Min	Thickness Max	Width Min	Width Max	Thickness Min	Thickness Max			Across Flats [A]	Across Corners	Weight Kgs
20S	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	6.3	11.7	4.0	7.0	7.9	11.7	4.5	7.0	0.10-0.30	81	30.0	33.0	0.273
20R	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	8.1	13.5	5.8	6.2	10.7	16.1	5.4	8.3	0.10-0.30	82	30.0	33.0	0.274
20	M20 x 1.5	1/2" or 3/4"	16	M20 x 1.5	1/2" or 3/4"	10.3	13.5	5.6	9.0	11.0	13.5	4.5	9.0	0.10-0.30	81	30.0	33.0	0.273

### NOTES

- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.

- Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Where approval in addition to ATEX & IECEX is required, this must be clearly requested at time of enquiry / order.